



## Fire & Rescue Services

---

**Eugene Campbell, Jr.**  
Fire Chief

*Service, Honor, Commitment*



To whom it may concern:

The Public Protection Classification (PPC) summary report prepared by the Insurance Services Office resulted in a Class 01/1Y classification for Missouri City; effective August 01, 2016. The attachments include an excerpt from the official report confirming the new classification rate.

If you have any further questions please feel free to contact our office at (281) 403-4326.

Sincerely,

Eugene Campbell, Jr.  
Fire Chief



Fire & Rescue Services

Eugene Campbell, Jr.  
Fire Chief

*Service, Honor, Commitment*



## ISO classification rules for Missouri City

Rules according to the Texas State Fire Marshal Office,

- Any property inside the city limits of Missouri City is an **ISO class I** (effective 8-1-2016) (regardless of water supply or distance from fire station)
- In areas outside of the city limits and within our response district (Outside Protected Area) which includes our ETJ and Sienna Plantation:
  - Property within 1000 feet of a fire hydrant **and within 5 miles** of a fire station is an **ISO class I**
  - Property that is more than 1000 feet from a fire hydrant **and within 5 miles** of a fire station is an **ISO class IY**
  - **ISO class I0**: applies to properties over 5 road miles of a recognized fire station.
  - **ISO class I0W**: applies to properties within 5 to 7 road miles of a recognized fire station with a recognized water supply within 1,000 feet.
  - Certified Alternative Water Supply: The first class (**Class I**) applies to properties within 5 road miles of a recognized fire station with no hydrant distance requirement.

*Note: the distance from the fire station is actual road miles.*

**INSURANCE SERVICES OFFICE, INC.  
CLASS 9 / CLASS 10 EVALUATION**

Community: <u>Missouri City OPA</u>	State: <u>TEXAS</u>
County: <u>TEXAS(Fort Bend),</u>	Population: <u>20000</u>
Field Rep: <u>Rawlings, Arthur</u>	Survey Date: <u>10/08/2015</u>
Equipment Credit: <u>92</u>	Class: <u>01/1Y</u>

Fire Alarms					
<u>2,000</u> Total number of alarms	Year the alarms were reported				
<b>Records</b>					
<i>Records for fire calls:</i>	<table border="0"> <tr> <td><u>1</u> Date</td> <td><u>1</u> Location of fires</td> </tr> <tr> <td><u>1</u> Time</td> <td><u>2</u> Number of responding members</td> </tr> </table>	<u>1</u> Date	<u>1</u> Location of fires	<u>1</u> Time	<u>2</u> Number of responding members
<u>1</u> Date	<u>1</u> Location of fires				
<u>1</u> Time	<u>2</u> Number of responding members				
<i>Records of meetings and training:</i>	<u>2</u> Training Sessions				
<i>Records of maintenance:</i>	<u>1</u> Maintenance of apparatus and equipment				
<i>Records of rosters include:</i>	<u>1</u> Current roster of fire department members				
<b>Total Points: <u>10</u></b>					

Recognition									
<i>Organization:</i>	<table border="0"> <tr> <td><u>TRUE</u></td> <td>Is the fire department organized on a permanent basis under applicable state or local laws?</td> </tr> <tr> <td><u>TRUE</u></td> <td>Is there one person responsible for the operation of the Fire Department?</td> </tr> <tr> <td><u>TRUE</u></td> <td>Does the area have definite boundaries?</td> </tr> <tr> <td><u>TRUE</u></td> <td>Is the fire department legally responsible for the fire protection by legal contract or resolution?</td> </tr> </table>	<u>TRUE</u>	Is the fire department organized on a permanent basis under applicable state or local laws?	<u>TRUE</u>	Is there one person responsible for the operation of the Fire Department?	<u>TRUE</u>	Does the area have definite boundaries?	<u>TRUE</u>	Is the fire department legally responsible for the fire protection by legal contract or resolution?
<u>TRUE</u>	Is the fire department organized on a permanent basis under applicable state or local laws?								
<u>TRUE</u>	Is there one person responsible for the operation of the Fire Department?								
<u>TRUE</u>	Does the area have definite boundaries?								
<u>TRUE</u>	Is the fire department legally responsible for the fire protection by legal contract or resolution?								
<i>Distribution:</i>	<u>TRUE</u> Is the responding fire department within 5 road miles from the fire protection area?								
<i>Membership:</i>	<u>TRUE</u> Do at least four members, one of whom may be a chief officer, respond to all fire alarms for fires in structures?								
<i>Training:</i>	<u>TRUE</u> Is training conducted for all active members for at least 3 hours every 3 months totalling at least 12 hours annually?								
<i>Alarm Notification:</i>	<u>TRUE</u> Are alarm facilities and dispatching procedures such that there is no delay in the receipt of alarms and dispatching of firefighters and apparatus?								
<i>Protective Clothing:</i>	<u>TRUE</u> Does each person credited have a protective clothing ensemble?								
<i>Housing:</i>	<u>TRUE</u> Is the apparatus housed (in a heated building, where necessary) so that it will be protected from the weather?								

INSURANCE SERVICES OFFICE, INC.  
Class 8B Eligibility

Community: Missouri City OPA  
County: TEXAS(Fort Bend),  
Class: 01/1Y

State: TEXAS  
Survey Date: 10/08/2015  
Eligible for Class 8B: TRUE

- 
- TRUE Does the combined primary fire department and automatic aid respond equal an average of 6 firefighters on first alarm responses to structure fires?
- TRUE Does the primary responding fire department (and automatic aid fire department(s), if applicable) conduct a minimum average of 24 hours of structural fire fighting training per year for each active firefighter?
- TRUE Can the fire department - on its own or with the help of automatic-aid fire departments deliver an uninterrupted fire flow of 200 gpm for 20 minutes, beginning within 5 minutes of the first arriving engine company to the built upon areas of their service area within five (all weather) road miles of a recognized fire station?
- TRUE Is the communication center(s) eligible for a credit of 4 points under Item 440 (Credit for Emergency Communications)?
- TRUE Does the fire department respond with an apparatus equipped to at least 40% according to section 512; taking into considerable pumping capacity, hose quantity and major equipment?